

CERTIFICATE OF COMPLIANCE

Certificate Number 20190614-E486740
Report Reference E486740-20171130
Issue Date 2019-JUNE-14

Issued to: TUBOS MEXICANOS FLEXIBLES S A DE C V
Av. Presidente Juarez 265
Col. San Jeronimo Tepetlactalco
54090 Tlalnepantla, Estado de Mexico MEXICO

**This certificate confirms that
representative samples of**

CONDUIT FITTINGS FOR USE IN HAZARDOUS
LOCATIONS

USL - Flexible Connection Fittings for use in Hazardous
Locations.

Class I, Groups C and D; Class II, Groups E, F, and G.
Model No. ETGJH followed by 1, 2, 3, 4, 5 or 6, followed by
4 through 36, may be followed by SS

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Standard No. UL 1203, 5th Ed., Rev. 2018-08-24,
Explosion-Proof and Dust-Ignition-Proof Electrical
Equipment for Use in Hazardous (Classified) Locations

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

